

GS331

Glasbreukdetector tester

Glass Break Tester

The tester GS331 is used to verify the operation of the glued-on-glass glass break detectors GS300/310. You test the detector by pressing the tester against the window. A noise will be heard simulating a glass breakage. It is recommended to test the glass break detectors before and after the installation.

Please note that this is not a range tester.



Details

- Automatic switching off
- Battery display via LED
- Test display via LED

GS331

Glasbreukdetector tester

Technische specificaties

Algemeen

Accessoire groep	Glasbreuksensoren
Type	Reserveonderdeel

Elektrisch

Type voeding	Batterijen
Waarde voeding	9 V battery
Bedrijfsspanning	6 to 10 VDC
Stroomverbruik	1 mA nominal at 12 VDC (standby) 60 mA nominal at 12 V (alarm)
Accupaciteit	Approx. 8 h operating time or 3000 activities (each 10 s)

Fysiek

Fysieke afmetingen	120 x 60 x25 mm
Netto gewicht	150 g

General

System indicator	Green LED blinks at pushed button mode
Battery indicator	Red LED